

STREET LIGHT



FOUNDATION

POLE DATA			ARM	FOUNDATION		ANCHOR BOLTS		
A HEIGHT	P MTG. HGT.	ACCEPTABLE PRODUCTS	M LENGTH	F DEPTH	Ø DIA	Ø SQ	SIZE	BOLT CIRCLE
22'-6"	25'-0"	VALAMONT DS 50 5.9A220-6S OR APPROVED EQUAL	6'	3'-4"	24"	20"	1" x 36" x 4"	9"
27'-6"	30'-0"	VALAMONT DS 50 6.6A270-6S OR APPROVED EQUAL	6'	5'-0"	30"	27"	1" x 36" x 4"	9 1/2"

NOTES:

- A. PULL BOX SHALL BE INSTALLED ADJACENT TO POLE WITHIN 36". PULL BOX SHALL NOT BE LOCATED IN SIDEWALK WITHOUT PRIOR APPROVAL OF THE CITY ENGINEER.
- B. WHEN A SECONDARY PULL BOX IS LOCATED WITHIN 8' OF POLE, PULL BOX IS NOT REQUIRED.

THE CITY OF WEST SACRAMENTO – STANDARD DETAIL

APPROVED BY:  CITY ENGINEER	C=38733 P.E. NO.	3/31/05 DATE	TITLE: STANDARD STREET LIGHT STANDARD DETAIL #: 602	
REVISION:				
REVISION:				
REVISION:				
REVISION:				